

SIMATIC S7-1500F, CPU 1515F-2 PN, central processing unit with 1.5 MB work memory for program and 4.5 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 6 ns bit performance, SIMATIC Memory Card required *** approvals and certificates according to entry 109817466 at to be considered! ***

| General information | |
|--|---|
| Product type designation | CPU 1515F-2 PN |
| HW functional status | FS01 |
| Firmware version | V3.0 |
| <ul style="list-style-type: none"> FW update possible | Yes |
| Product function | |
| <ul style="list-style-type: none"> I&M data | Yes; I&M0 to I&M3 |
| <ul style="list-style-type: none"> Isochronous mode | Yes; Distributed and central; with minimum OB 6x cycle of 375 µs (distributed) and 1 ms (central) |
| Engineering with | |
| <ul style="list-style-type: none"> STEP 7 TIA Portal configurable/integrated from version | V18 (FW V3.0); with older TIA Portal versions configurable as 6ES7515-2FM02-0AB0 |
| Configuration control | |
| via dataset | Yes |
| Display | |
| Screen diagonal [cm] | 6.1 cm |
| Control elements | |
| Number of keys | 8 |
| Mode buttons | 2 |
| Supply voltage | |
| Rated value (DC) | 24 V |
| permissible range, lower limit (DC) | 19.2 V |
| permissible range, upper limit (DC) | 28.8 V |
| Reverse polarity protection | Yes |
| Mains buffering | |
| <ul style="list-style-type: none"> Mains/voltage failure stored energy time | 5 ms |
| <ul style="list-style-type: none"> Repeat rate, min. | 1/s |
| Input current | |
| Current consumption (rated value) | 0.83 A |
| Current consumption, max. | 1.03 A |
| Inrush current, max. | 1.15 A; Rated value |
| I^2t | 0.6 A ² s |
| Power | |
| Infeed power to the backplane bus | 12 W |
| Power consumption from the backplane bus (balanced) | 6.2 W |
| Power loss | |
| Power loss, typ. | 7.9 W |
| Memory | |
| Number of slots for SIMATIC memory card | 1 |
| SIMATIC memory card required | Yes |
| Work memory | |
| <ul style="list-style-type: none"> integrated (for program) | 1.5 Mbyte |
| <ul style="list-style-type: none"> integrated (for data) | 4.5 Mbyte |
| Load memory | |
| <ul style="list-style-type: none"> Plug-in (SIMATIC Memory Card), max. | 32 Gbyte |
| Backup | |
| <ul style="list-style-type: none"> maintenance-free | Yes |
| CPU processing times | |
| for bit operations, typ. | 6 ns |

| | |
|--|---|
| for word operations, typ. | 7 ns |
| for fixed point arithmetic, typ. | 9 ns |
| for floating point arithmetic, typ. | 37 ns |
| CPU-blocks | |
| Number of elements (total) | 8 000; Blocks (OB, FB, FC, DB) and UDTs |
| DB | |
| • Number range | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999 |
| • Size, max. | 4.5 Mbyte; For DBs with absolute addressing, the max. size is 64 KB |
| FB | |
| • Number range | 0 ... 65 535 |
| • Size, max. | 1 Mbyte |
| FC | |
| • Number range | 0 ... 65 535 |
| • Size, max. | 1 Mbyte |
| OB | |
| • Size, max. | 1 Mbyte |
| • Number of free cycle OBs | 100 |
| • Number of time alarm OBs | 20 |
| • Number of delay alarm OBs | 20 |
| • Number of cyclic interrupt OBs | 20; With minimum OB 3x cycle of 250 µs |
| • Number of process alarm OBs | 50 |
| • Number of DPV1 alarm OBs | 3 |
| • Number of isochronous mode OBs | 2 |
| • Number of technology synchronous alarm OBs | 2 |
| • Number of startup OBs | 100 |
| • Number of asynchronous error OBs | 4 |
| • Number of synchronous error OBs | 2 |
| • Number of diagnostic alarm OBs | 1 |
| Nesting depth | |
| • per priority class | 24; Up to 8 possible for F-blocks |
| Counters, timers and their retentivity | |
| S7 counter | |
| • Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC counter | |
| • Number | Any (only limited by the main memory) |
| Retentivity | |
| — adjustable | Yes |
| S7 times | |
| • Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC timer | |
| • Number | Any (only limited by the main memory) |
| Retentivity | |
| — adjustable | Yes |
| Data areas and their retentivity | |
| Retentive data area (incl. timers, counters, flags), max. | 512 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 472 KB |
| Extended retentive data area (incl. timers, counters, flags), max. | 4.5 Mbyte; When using PS 6 0W 24/48/60 V DC HF |
| Flag | |
| • Size, max. | 16 kbyte |
| • Number of clock memories | 8; 8 clock memory bit, grouped into one clock memory byte |
| Data blocks | |
| • Retentivity adjustable | Yes |
| • Retentivity preset | No |
| Local data | |
| • per priority class, max. | 64 kbyte; max. 16 KB per block |
| Address area | |

| | |
|-------------------------------------|---|
| Number of IO modules | 8 192; max. number of modules / submodules |
| I/O address area | |
| • Inputs | 32 kbyte; All inputs are in the process image |
| • Outputs | 32 kbyte; All outputs are in the process image |
| per integrated IO subsystem | |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| per CM/CP | |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| Subprocess images | |
| • Number of subprocess images, max. | 32 |
| Hardware configuration | |
| Number of distributed IO systems | 64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| Number of DP masters | |
| • Via CM | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total |
| Number of IO Controllers | |
| • integrated | 2 |
| • Via CM | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total |
| Rack | |
| • Modules per rack, max. | 32; CPU + 31 modules |
| • Number of lines, max. | 1 |
| PtP CM | |
| • Number of PtP CMs | the number of connectable PtP CMs is only limited by the number of available slots |
| Time of day | |
| Clock | |
| • Type | Hardware clock |
| • Backup time | 6 wk; At 40 °C ambient temperature, typically |
| • Deviation per day, max. | 10 s; Typ.: 2 s |
| Operating hours counter | |
| • Number | 16 |
| Clock synchronization | |
| • supported | Yes |
| • in AS, master | Yes |
| • in AS, slave | Yes |
| • on Ethernet via NTP | Yes |
| Interfaces | |
| Number of PROFINET interfaces | 2 |
| 1. Interface | |
| Interface types | |
| • RJ 45 (Ethernet) | Yes; X1 |
| • Number of ports | 2 |
| • integrated switch | Yes |
| Protocols | |
| • IP protocol | Yes; IPv4 |
| • PROFINET IO Controller | Yes |
| • PROFINET IO Device | Yes |
| • SIMATIC communication | Yes |
| • Open IE communication | Yes; Optionally also encrypted |
| • Web server | Yes |
| • Media redundancy | Yes |
| PROFINET IO Controller | |
| Services | |
| — PG/OP communication | Yes |
| — Isochronous mode | Yes |
| — Direct data exchange | Yes; Requirement: IRT and isochronous mode (MRPD optional) |
| — IRT | Yes |

| | |
|---|--|
| — PROFINergy | Yes; per user program |
| — Prioritized startup | Yes; Max. 32 PROFINET devices |
| — Number of connectable IO Devices, max. | 256; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| — Of which IO devices with IRT, max. | 64 |
| — Number of connectable IO Devices for RT, max. | 256 |
| — of which in line, max. | 256 |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces |
| — Number of IO Devices per tool, max. | 8 |
| — Updating times | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |

Update time for IRT

| | |
|--|---|
| — for send cycle of 250 µs | 250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 375 µs of the isochronous OB is decisive |
| — for send cycle of 500 µs | 500 µs to 8 ms |
| — for send cycle of 1 ms | 1 ms to 16 ms |
| — for send cycle of 2 ms | 2 ms to 32 ms |
| — for send cycle of 4 ms | 4 ms to 64 ms |
| — With IRT and parameterization of "odd" send cycles | Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs) |

Update time for RT

| | |
|----------------------------|------------------|
| — for send cycle of 250 µs | 250 µs to 128 ms |
| — for send cycle of 500 µs | 500 µs to 256 ms |
| — for send cycle of 1 ms | 1 ms to 512 ms |
| — for send cycle of 2 ms | 2 ms to 512 ms |
| — for send cycle of 4 ms | 4 ms to 512 ms |

PROFINET IO Device

Services

| | |
|---|-----------------------|
| — PG/OP communication | Yes |
| — Isochronous mode | No |
| — IRT | Yes |
| — PROFINergy | Yes; per user program |
| — Shared device | Yes |
| — Number of IO Controllers with shared device, max. | 4 |
| — activation/deactivation of I-devices | Yes; per user program |
| — Asset management record | Yes; per user program |

2. Interface

Interface types

| | |
|---------------------|---------|
| ● RJ 45 (Ethernet) | Yes; X2 |
| ● Number of ports | 1 |
| ● integrated switch | No |

Protocols

| | |
|--------------------------|--------------------------------|
| ● IP protocol | Yes; IPv4 |
| ● PROFINET IO Controller | Yes |
| ● PROFINET IO Device | Yes |
| ● SIMATIC communication | Yes |
| ● Open IE communication | Yes; Optionally also encrypted |
| ● Web server | Yes |
| ● Media redundancy | No |

PROFINET IO Controller

Services

| | |
|---|---|
| — PG/OP communication | Yes |
| — Isochronous mode | No |
| — Direct data exchange | No |
| — IRT | No |
| — PROFINergy | Yes; per user program |
| — Prioritized startup | No |
| — Number of connectable IO Devices, max. | 32; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| — Number of connectable IO Devices for RT, max. | 32 |
| — of which in line, max. | 32 |

- Number of IO Devices that can be simultaneously activated/deactivated, max.
- Number of IO Devices per tool, max.
- Updating times

8; in total across all interfaces

8

The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data

Update time for RT

- for send cycle of 1 ms

1 ms to 512 ms

PROFINET IO Device

Services

- PG/OP communication
- Isochronous mode
- IRT
- PROFIenergy
- Prioritized startup
- Shared device
- Number of IO Controllers with shared device, max.
- activation/deactivation of I-devices
- Asset management record

Yes
No
No
Yes; per user program
No
Yes
4
Yes; per user program
Yes; per user program

Interface types

RJ 45 (Ethernet)

- 100 Mbps
- Autonegotiation
- Autocrossing
- Industrial Ethernet status LED

Yes
Yes
Yes
Yes

Protocols

PROFIsafe

Yes; V2.4 / V2.6

Number of connections

- Number of connections, max.
- Number of connections reserved for ES/HMI/web
- Number of connections via integrated interfaces
- Number of S7 routing paths

256; via integrated interfaces of the CPU and connected CPs / CMs
10
128
16

Redundancy mode

- H-Sync forwarding

Yes

Media redundancy

- Media redundancy
- MRP
- MRP interconnection, supported
- MRPD
- Switchover time on line break, typ.
- Number of stations in the ring, max.

only via 1st interface (X1)
Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client
Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
Yes; Requirement: IRT
200 ms; For MRP, bumpless for MRPD
50

SIMATIC communication

- PG/OP communication
- S7 routing
- Data record routing
- S7 communication, as server
- S7 communication, as client
- User data per job, max.

Yes; encryption with TLS V1.3 pre-selected
Yes
Yes
Yes
Yes
See online help (S7 communication, user data size)

Open IE communication

- TCP/IP
 - Data length, max.
 - several passive connections per port, supported
- ISO-on-TCP (RFC1006)
 - Data length, max.
- UDP
 - Data length, max.
 - UDP multicast
- DHCP
- DNS
- SNMP
- DCP

Yes
64 kbyte
Yes
Yes
Yes
2 kbyte; 1 472 bytes for UDP broadcast
Yes; max. 118 multicast circuits
Yes
Yes
Yes
Yes

| | |
|--|---|
| <ul style="list-style-type: none"> • LLDP • Encryption | <p>Yes</p> <p>Yes; Optional</p> |
| Web server | |
| <ul style="list-style-type: none"> • HTTP • HTTPS | <p>Yes; Standard and user pages</p> <p>Yes; Standard and user pages</p> |
| OPC UA | |
| <ul style="list-style-type: none"> • Runtime license required • OPC UA Client <ul style="list-style-type: none"> — Application authentication — Security policies — User authentication — Number of connections, max. — Number of nodes of the client interfaces, recommended max. — Number of elements for one call of OPC-UA_NodeGetHandleList/OPC-UA_ReadList/OPC-UA_WriteList, max. — Number of elements for one call of OPC-UA_NameSpaceGetIndexList, max. — Number of elements for one call of OPC-UA_MethodGetHandleList, max. — Number of simultaneous calls of the client instructions for session management, per connection, max. — Number of simultaneous calls of the client instructions for data access, per connection, max. — Number of registerable nodes, max. — Number of registerable method calls of OPC-UA_MethodCall, max. — Number of inputs/outputs when calling OPC-UA_MethodCall, max. • OPC UA Server <ul style="list-style-type: none"> — Application authentication — Security policies — User authentication — GDS support (certificate management) — Number of sessions, max. — Number of accessible variables, max. — Number of registerable nodes, max. — Number of subscriptions per session, max. — Sampling interval, min. — Publishing interval, min. — Number of server methods, max. — Number of inputs/outputs per server method, max. — Number of monitored items, recommended max. — Number of server interfaces, max. — Number of nodes for user-defined server interfaces, max. • Alarms and Conditions <ul style="list-style-type: none"> — Number of program alarms — Number of alarms for system diagnostics | <p>Yes; "Medium" license required</p> <p>Yes; Data Access (registered Read/Write), Method Call</p> <p>Yes</p> <p>Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256</p> <p>"anonymous" or by user name & password</p> <p>10</p> <p>2 000</p> <p>300</p> <p>20</p> <p>100</p> <p>1</p> <p>5</p> <p>5 000</p> <p>100</p> <p>20</p> <p>Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space</p> <p>Yes</p> <p>available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss</p> <p>"anonymous" or by user name & password</p> <p>Yes</p> <p>48</p> <p>100 000</p> <p>20 000</p> <p>50</p> <p>100 ms</p> <p>100 ms</p> <p>50</p> <p>20</p> <p>4 000; for 1 s sampling interval and 1 s send interval</p> <p>10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"</p> <p>30 000</p> <p>Yes</p> <p>200</p> <p>100</p> |
| Further protocols | |
| <ul style="list-style-type: none"> • MODBUS | <p>Yes; MODBUS TCP</p> |
| S7 message functions | |
| <ul style="list-style-type: none"> • Number of login stations for message functions, max. | <p>64</p> |
| <ul style="list-style-type: none"> • Program alarms | <p>Yes</p> |
| <ul style="list-style-type: none"> • Number of configurable program messages, max. | <p>10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH</p> |
| <ul style="list-style-type: none"> • Number of loadable program messages in RUN, max. | <p>5 000</p> |
| <ul style="list-style-type: none"> • Number of simultaneously active program alarms • Number of program alarms | <p>1 000</p> |

| | |
|---|---|
| • Number of alarms for system diagnostics | 200 |
| • Number of alarms for motion technology objects | 160 |
| Test commissioning functions | |
| Joint commission (Team Engineering) | Yes; Parallel online access possible for up to 8 engineering systems |
| Status block | Yes; Up to 8 simultaneously (in total across all ES clients) |
| Single step | No |
| Number of breakpoints | 8 |
| Status/control | |
| • Status/control variable | Yes; without fail-safe |
| • Variables | inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters |
| • Number of variables, max. | |
| — of which status variables, max. | 200; per job |
| — of which control variables, max. | 200; per job |
| Forcing | |
| • Forcing | Yes; without fail-safe |
| • Forcing, variables | peripheral inputs/outputs (without fail-safe) |
| • Number of variables, max. | 200 |
| Diagnostic buffer | |
| • present | Yes |
| • Number of entries, max. | 3 200 |
| — of which powerfail-proof | 500 |
| Traces | |
| • Number of configurable Traces | 4; Up to 512 KB of data per trace are possible |
| Interrupts/diagnostics/status information | |
| Diagnostics indication LED | |
| • RUN/STOP LED | Yes |
| • ERROR LED | Yes |
| • MAINT LED | Yes |
| • STOP ACTIVE LED | Yes |
| • Connection display LINK TX/RX | Yes |
| Supported technology objects | |
| Motion Control | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool |
| • Number of available Motion Control resources for technology objects | 2 400 |
| • Required Motion Control resources | |
| — per speed-controlled axis | 40 |
| — per positioning axis | 80 |
| — per synchronous axis | 160 |
| — per external encoder | 80 |
| — per output cam | 20 |
| — per cam track | 160 |
| — per probe | 40 |
| • Positioning axis | |
| — Number of positioning axes at motion control cycle of 4 ms (typical value) | 11 |
| — Number of positioning axes at motion control cycle of 8 ms (typical value) | 20 |
| Controller | |
| • PID_Compact | Yes; Universal PID controller with integrated optimization |
| • PID_3Step | Yes; PID controller with integrated optimization for valves |
| • PID-Temp | Yes; PID controller with integrated optimization for temperature |
| Counting and measuring | |
| • High-speed counter | Yes |
| Standards, approvals, certificates | |
| Highest safety class achievable in safety mode | |
| • Performance level according to ISO 13849-1 | PLe |
| • SIL acc. to IEC 61508 | SIL 3 |
| Probability of failure (for service life of 20 years and repair time of 100 hours) | |
| — Low demand mode: PFDavg in accordance with SIL3 | < 2.00E-05 |

— High demand/continuous mode: PFH in accordance with SIL3 < 1.00E-09

Ambient conditions

| | |
|---|--|
| Ambient temperature during operation | |
| • horizontal installation, min. | -30 °C; No condensation |
| • horizontal installation, max. | 60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off |
| • vertical installation, min. | -30 °C; No condensation |
| • vertical installation, max. | 40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off |
| Ambient temperature during storage/transportation | |
| • min. | -40 °C |
| • max. | 70 °C |
| Altitude during operation relating to sea level | |
| • Installation altitude above sea level, max. | 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual |

configuration / header

| | |
|---|-------------------------------|
| configuration / programming / header | |
| Programming language | |
| — LAD | Yes; incl. failsafe |
| — FBD | Yes; incl. failsafe |
| — STL | Yes |
| — SCL | Yes |
| — GRAPH | Yes |
| Know-how protection | |
| • User program protection/password protection | Yes |
| • Copy protection | Yes |
| • Block protection | Yes |
| Access protection | |
| • protection of confidential configuration data | Yes |
| • Password for display | Yes |
| • Protection level: Write protection | Yes |
| • Protection level: Read/write protection | Yes |
| • Protection level: Write protection for Failsafe | Yes |
| • Protection level: Complete protection | Yes |
| programming / cycle time monitoring / header | |
| • lower limit | adjustable minimum cycle time |
| • upper limit | adjustable maximum cycle time |
| Dimensions | |
| Width | 70 mm |
| Height | 147 mm |
| Depth | 129 mm |
| Weights | |
| Weight, approx. | 456 g |

last modified: 4/2/2023 