



SIMATIC DP, IM154-8 PN/DP CPU f. ET200 PRO, 384 KB work memory, Int. PROFINET interface, Int. PROFIBUS DP master/slave interface Degree of protection IP65/67, Micro Memory Card and Connection module required

General information	
HW functional status	01
Firmware version	V3.2
Product function	
<ul style="list-style-type: none"> <li>• Isochronous mode</li> </ul>	Yes; Via PROFIBUS DP or PROFINET interface
Engineering with	
<ul style="list-style-type: none"> <li>• Programming package</li> </ul>	STEP 7 V5.5 or higher
Supply voltage	
Rated value (DC)	24 V
external protection for power supply lines (recommendation)	MCB 24 V DC / 16 A with tripping characteristic Type B and C (see ET 200pro manual)
Load voltage L+	
<ul style="list-style-type: none"> <li>• Rated value (DC)</li> <li>• permissible range, lower limit (DC)</li> <li>• permissible range, upper limit (DC)</li> <li>• Reverse polarity protection</li> </ul>	24 V 20.4 V 28.8 V Yes
Input current	
Current consumption, typ.	350 mA
Current consumption (in no-load operation), typ.	250 mA; Typical, current consumption for CPU in STOP state
Inrush current, typ.	2 A
I <sup>2</sup> t	0.25 A <sup>2</sup> ·s; Typical
Power loss	
Power loss, typ.	8.5 W
Memory	
Work memory	
<ul style="list-style-type: none"> <li>• integrated</li> <li>• expandable</li> </ul>	384 kbyte No
Load memory	
<ul style="list-style-type: none"> <li>• Plug-in (MMC)</li> <li>• Plug-in (MMC), max.</li> <li>• Data management on MMC (after last programming), min.</li> </ul>	Yes 8 Mbyte 10 a
Backup	
<ul style="list-style-type: none"> <li>• present</li> <li>• without battery</li> </ul>	Yes; Guaranteed by MMC (maintenance-free) Yes; Program and data
CPU processing times	
for bit operations, typ.	0.05 μs
for word operations, typ.	0.09 μs
for fixed point arithmetic, typ.	0.12 μs
for floating point arithmetic, typ.	0.45 μs

**CPU-blocks**

Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used.
--------------------------	---

**DB**

<ul style="list-style-type: none"> <li>• Number, max.</li> <li>• Size, max.</li> </ul>	1 024; Number range: 1 to 16000 64 kbyte
--	---

**FB**

<ul style="list-style-type: none"> <li>• Number, max.</li> <li>• Size, max.</li> </ul>	1 024; Number range: 0 to 7999 64 kbyte
--	--

**FC**

<ul style="list-style-type: none"> <li>• Number, max.</li> <li>• Size, max.</li> </ul>	1 024; Number range: 0 to 7999 64 kbyte
--	--

**OB**

<ul style="list-style-type: none"> <li>• Size, max.</li> <li>• Number of free cycle OBs</li> <li>• Number of time alarm OBs</li> <li>• Number of delay alarm OBs</li> <li>• Number of cyclic interrupt OBs</li> <li>• Number of process alarm OBs</li> <li>• Number of DPV1 alarm OBs</li> <li>• Number of isochronous mode OBs</li> <li>• Number of startup OBs</li> <li>• Number of asynchronous error OBs</li> <li>• Number of synchronous error OBs</li> </ul>	64 kbyte 1; OB 1 1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for centralized I/O and PROFINET IO) 2; OB 121, 122
--	--

**Nesting depth**

<ul style="list-style-type: none"> <li>• per priority class</li> <li>• additional within an error OB</li> </ul>	16 4
---	---------

**Counters, timers and their retentivity****S7 counter**

<ul style="list-style-type: none"> <li>• Number</li> </ul>	256
--	-----

**Retentivity**

— adjustable	Yes
— preset	Z 0 to Z 7

**Counting range**

— adjustable	Yes
— lower limit	0
— upper limit	999

**IEC counter**

<ul style="list-style-type: none"> <li>• present</li> <li>• Type</li> <li>• Number</li> </ul>	Yes SFB Unlimited (limited only by RAM capacity)
---	--

**S7 times**

<ul style="list-style-type: none"> <li>• Number</li> </ul>	256
--	-----

**Retentivity**

— adjustable	Yes
— preset	No retentivity

**Time range**

— lower limit	10 ms
— upper limit	9 990 s

**IEC timer**

<ul style="list-style-type: none"> <li>• present</li> <li>• Type</li> <li>• Number</li> </ul>	Yes SFB Unlimited (limited only by RAM capacity)
---	--

**Data areas and their retentivity**

Retentive data area (incl. timers, counters, flags), max.	128 kbyte
---	-----------

**Flag**

<ul style="list-style-type: none"> <li>• Size, max.</li> <li>• Retentivity available</li> <li>• Retentivity preset</li> <li>• Number of clock memories</li> </ul>	2 048 byte Yes; MB 0 to MB 2 047 MB 0 to MB 15 8
---	---

**Data blocks**

<ul style="list-style-type: none"> <li>• Retentivity adjustable</li> <li>• Retentivity preset</li> </ul>	<p>Yes; via non-retain property on DB</p> <p>Yes</p>
<b>Local data</b>	
<ul style="list-style-type: none"> <li>• per priority class, max.</li> </ul>	32 768 byte; Max. 2048 bytes per block
<b>Address area</b>	
<b>I/O address area</b>	
<ul style="list-style-type: none"> <li>• Inputs</li> <li>• Outputs</li> </ul>	<p>2 048 byte</p> <p>2 048 byte</p>
of which distributed	
<ul style="list-style-type: none"> <li>— Inputs</li> <li>— Outputs</li> </ul>	<p>2 048 byte</p> <p>2 048 byte</p>
<b>Process image</b>	
<ul style="list-style-type: none"> <li>• Inputs, adjustable</li> <li>• Outputs, adjustable</li> <li>• Inputs, default</li> <li>• Outputs, default</li> </ul>	<p>2 048 byte</p> <p>2 048 byte</p> <p>128 byte</p> <p>128 byte</p>
<b>Subprocess images</b>	
<ul style="list-style-type: none"> <li>• Number of subprocess images, max.</li> </ul>	1; With PROFINET IO, the length of the user data is limited to 1600 bytes
<b>Digital channels</b>	
<ul style="list-style-type: none"> <li>• Inputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> <li>• Outputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> </ul>	<p>16 384</p> <p>128</p> <p>16 384</p> <p>64</p>
<b>Analog channels</b>	
<ul style="list-style-type: none"> <li>• Inputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> <li>• Outputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> </ul>	<p>1 024</p> <p>64</p> <p>1 024</p> <p>64</p>
<b>Hardware configuration</b>	
Integrated power supply	Yes; 24 V DC
<b>Number of DP masters</b>	
<ul style="list-style-type: none"> <li>• integrated</li> </ul>	1
<b>Rack</b>	
<ul style="list-style-type: none"> <li>• Racks, max.</li> <li>• Modules per rack, max.</li> </ul>	<p>1</p> <p>16; Expansion width max. 1 m</p>
<b>Time of day</b>	
<b>Clock</b>	
<ul style="list-style-type: none"> <li>• Hardware clock (real-time)</li> <li>• retentive and synchronizable</li> <li>• Backup time</li> <li>• Deviation per day, max.</li> </ul>	<p>Yes</p> <p>Yes</p> <p>6 wk; At 40 °C ambient temperature</p> <p>10 s; Typ.: 2 s</p>
<b>Operating hours counter</b>	
<ul style="list-style-type: none"> <li>• Number</li> <li>• Number/Number range</li> <li>• Range of values</li> <li>• Granularity</li> <li>• retentive</li> </ul>	<p>1</p> <p>0</p> <p>0 to 2<sup>31</sup> hours (when using SFC 101)</p> <p>1 h</p> <p>Yes; Must be restarted at each restart</p>
<b>Clock synchronization</b>	
<ul style="list-style-type: none"> <li>• supported</li> <li>• to MPI, master</li> <li>• to MPI, slave</li> <li>• to DP, master</li> <li>• to DP, slave</li> <li>• on Ethernet via NTP</li> </ul>	<p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes; With DP slave only slave clock</p> <p>Yes</p> <p>Yes; As client</p>
<b>Interfaces</b>	
Interfaces/bus type	1x MPI/PROFIBUS DP, 1x PROFINET (3 ports)
<b>1. Interface</b>	
Interface type	Integrated RS 485 interface
Isolated	Yes
Interface types	

• RS 485	Yes
• Output current of the interface, max.	May only be used for external terminating resistor
• Design of the connection	2x M12 B-coded
<b>Protocols</b>	
• MPI	Yes
• PROFIBUS DP master	Yes
• PROFIBUS DP slave	Yes
• Point-to-point connection	No
<b>MPI</b>	
• Transmission rate, max.	12 Mbit/s
<b>Services</b>	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	Yes
— S7 basic communication	Yes
— S7 communication	Yes
— S7 communication, as client	No
— S7 communication, as server	Yes
<b>PROFIBUS DP master</b>	
• Transmission rate, max.	12 Mbit/s
• Number of DP slaves, max.	124
<b>Services</b>	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No
— S7 basic communication	Yes; I blocks only
— S7 communication	Yes
— S7 communication, as client	No
— S7 communication, as server	Yes; Connection configured on one side only
— Equidistance	Yes
— Isochronous mode	Yes; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously)
— SYNC/FREEZE	Yes
— Activation/deactivation of DP slaves	Yes
— Direct data exchange (slave-to-slave communication)	Yes; as subscriber
— DPV1	Yes
<b>Address area</b>	
— Inputs, max.	2 048 byte
— Outputs, max.	2 048 byte
<b>User data per DP slave</b>	
— Inputs, max.	244 byte
— Outputs, max.	244 byte
<b>PROFIBUS DP slave</b>	
• Transmission rate, max.	12 Mbit/s
• automatic baud rate search	Yes; only with passive interface
• Address area, max.	32
• User data per address area, max.	32 byte
<b>Services</b>	
— Routing	Yes; with interface active
— Global data communication	No
— S7 basic communication	No
— S7 communication	Yes
— S7 communication, as client	No
— S7 communication, as server	Yes; Connection configured on one side only
— Direct data exchange (slave-to-slave communication)	Yes
— DPV1	No
<b>Transfer memory</b>	
— Inputs	244 byte
— Outputs	244 byte

## 2. Interface

Interface type	PROFINET
Isolated	Yes; Galvanic isolation for P3 is implemented in IM154-8, for P1 and P2 in CM
automatic detection of transmission rate	Yes; 10/100 Mbit/s
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	Yes
<b>Interface types</b>	
<ul style="list-style-type: none"> <li>• Number of ports</li> <li>• integrated switch</li> <li>• Design of the connection</li> </ul>	<p>3</p> <p>Yes</p> <p>Ethernet (2x M12 D-coded; 1x RJ45)</p>
<b>Protocols</b>	
<ul style="list-style-type: none"> <li>• MPI</li> <li>• PROFINET IO Controller</li> <li>• PROFINET IO Device</li> <li>• PROFINET CBA</li> <li>• PROFIBUS DP master</li> <li>• PROFIBUS DP slave</li> <li>• Open IE communication</li> <li>• Web server</li> <li>• Media redundancy</li> </ul>	<p>No</p> <p>Yes; Also simultaneously with IO-Device functionality</p> <p>Yes; Also simultaneously with IO Controller functionality</p> <p>Yes</p> <p>No</p> <p>No</p> <p>Yes; Via TCP/IP, ISO on TCP, and UDP</p> <p>Yes</p> <p>Yes</p>
<b>PROFINET IO Controller</b>	
<ul style="list-style-type: none"> <li>• Transmission rate, max.</li> </ul>	100 Mbit/s
<b>Services</b>	
<ul style="list-style-type: none"> <li>— PG/OP communication</li> <li>— Routing</li> <li>— S7 communication</li> <li>— Isochronous mode</li> <li>— IRT</li> <li>— Shared device</li> <li>— Prioritized startup</li> <li>— Number of IO devices with prioritized startup, max.</li> <li>— Number of connectable IO Devices, max.</li> <li>— Of which IO devices with IRT, max.</li> <li>— of which in line, max.</li> <li>— Number of IO Devices with IRT and the option "high flexibility"</li> <li>— of which in line, max.</li> <li>— Number of connectable IO Devices for RT, max.</li> <li>— of which in line, max.</li> <li>— Activation/deactivation of IO Devices</li> <li>— Number of IO Devices that can be simultaneously activated/deactivated, max.</li> <li>— IO Devices changing during operation (partner ports), supported</li> <li>— Number of IO Devices per tool, max.</li> <li>— Device replacement without swap medium</li> <li>— Send cycles</li> <li>— Updating time</li> </ul>	<p>Yes</p> <p>Yes</p> <p>Yes; With loadable FBs, max. configurable connections: 14, max. number of instances: 32</p> <p>Yes; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously)</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>32</p> <p>128</p> <p>64</p> <p>64</p> <p>128</p> <p>61</p> <p>128</p> <p>128</p> <p>Yes</p> <p>8</p> <p>Yes</p> <p>8</p> <p>Yes</p> <p>250 µs, 500 µs, 1 ms; 2 ms, 4 ms (not in the case of IRT with "high flexibility" option)</p> <p>250 µs to 512 ms (depending on the operating mode, see "IM 154-8 CPU Interface Module" operating instructions for more details)</p>
<b>Address area</b>	
<ul style="list-style-type: none"> <li>— Inputs, max.</li> <li>— Outputs, max.</li> <li>— User data consistency, max.</li> </ul>	<p>2 048 byte</p> <p>2 048 byte</p> <p>1 024 byte</p>
<b>PROFINET IO Device</b>	
<b>Services</b>	
<ul style="list-style-type: none"> <li>— PG/OP communication</li> <li>— Routing</li> <li>— S7 communication</li> </ul>	<p>Yes</p> <p>Yes</p> <p>Yes; With loadable FBs, max. configurable connections: 14, max. number of instances: 32</p>

— Isochronous mode	No
— IRT	Yes
— PROFINergy	Yes; With SFB 73 / 74 prepared for loadable PROFINergy standard FB for I-Device
— Shared device	Yes
— Number of IO Controllers with shared device, max.	2
<b>Transfer memory</b>	
— Inputs, max.	1 440 byte; Per IO Controller with shared device
— Outputs, max.	1 440 byte; Per IO Controller with shared device
<b>Submodules</b>	
— Number, max.	64
— User data per submodule, max.	1 024 byte
<b>PROFINET CBA</b>	
• acyclic transmission	Yes
• cyclic transmission	Yes
<b>Open IE communication</b>	
• Number of connections, max.	8
• Local port numbers used at the system end	0, 20, 21, 23, 25, 80, 102, 135, 161, 443, 8080, 34962, 34963, 34964, 65532, 65533, 65534, 65535
• Keep-alive function, supported	Yes
<b>Protocols</b>	
<b>Redundancy mode</b>	
<b>Media redundancy</b>	
— Switchover time on line break, typ.	200 ms; PROFINET MRP
— Number of stations in the ring, max.	50
<b>SIMATIC communication</b>	
• S7 routing	Yes
<b>Open IE communication</b>	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
— Number of connections, max.	8
— Data length, max.	32 768 byte; 1 460 bytes with connection type 01H; 32 768 bytes with connection type 11H
— several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Number of connections, max.	8
— Data length, max.	32 768 byte
• UDP	Yes
— Number of connections, max.	8
— Data length, max.	1 472 byte
<b>Web server</b>	
• supported	Yes
• User-defined websites	Yes
• Number of HTTP clients	5
<b>communication functions / header</b>	
PG/OP communication	Yes
<b>Global data communication</b>	
• supported	Yes
• Number of GD loops, max.	8
• Number of GD packets, max.	8
• Number of GD packets, transmitter, max.	8
• Number of GD packets, receiver, max.	8
• Size of GD packets, max.	22 byte
• Size of GD packet (of which consistent), max.	22 byte
<b>S7 basic communication</b>	
• communication function / S7 basic communication	Yes
• User data per job, max.	76 byte
• User data per job (of which consistent), max.	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server)
<b>S7 communication</b>	
• supported	Yes
• as server	Yes
• as client	Yes; via integrated PROFINET interface and loadable FBs

• User data per job, max.	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)
<b>communication functions / PROFINET CBA (with set target communication load) / header</b>	
• Setpoint for the CPU communication load	50 %
• Number of remote interconnection partners	32
• Number of functions, master/slave	30
• Total of all master/slave connections	1 000
• Data length of all incoming connections master/slave, max.	4 000 byte
• Data length of all outgoing connections master/slave, max.	4 000 byte
• Number of device-internal and PROFIBUS interconnections	500
• Data length of device-internal und PROFIBUS interconnections, max.	4 000 byte
• Data length per connection, max.	1 400 byte
<b>performance data / PROFINET CBA / remote interconnection / with acyclic transfer / header</b>	
— Sampling interval, min.	500 ms
— Number of incoming interconnections	100
— Number of outgoing interconnections	100
— Data length of all incoming interconnections, max.	2 000 byte
— Data length of all outgoing interconnections, max.	2 000 byte
— data volume / as user data for remote interconnections / in the case of acyclic transmission / with PROFINET CBA / per connection / maximum	1 400 byte
<b>performance data / PROFINET CBA / remote interconnection / with cyclic transfer / header</b>	
— Transmission frequency: Transmission interval, min.	1 ms
— number of remote connections to input variables / with PROFINET CBA / with cyclic transfer / maximum	200
— number of remote connections to output variables / with cyclical transfer / with PROFINET CBA / maximum	200
— data volume / as user data for remote interconnections with input variables / with cyclical transfer / with PROFINET CBA / maximum	2 000 byte
— data volume / as user data for remote interconnections with output variables / with cyclical transfer / with PROFINET CBA / maximum	2 000 byte
— data volume / as user data for remote interconnections / with cyclical transfer / with PROFINET CBA / per connection / maximum	450 byte
<b>performance data / PROFINET CBA / HMI variables via PROFINET / acyclic / header</b>	
— Number of stations that can log on for HMI variables (PN OPC/iMap)	3; 2x PN OPC/1x iMap
— HMI variable updating	500 ms
— Number of HMI variables	200
— Data length of all HMI variables, max.	2 000 byte
<b>performance data / PROFINET CBA / PROFIBUS proxy functionality / header</b>	
— supported	Yes
— Number of linked PROFIBUS devices	16
— Data length per connection, max.	240 byte; Slave-dependent
<b>Number of connections</b>	
• overall	16
• usable for PG communication	15
— reserved for PG communication	1
— adjustable for PG communication, min.	1
— adjustable for PG communication, max.	15
• usable for OP communication	15
— reserved for OP communication	1
— adjustable for OP communication, min.	1
— adjustable for OP communication, max.	15
• usable for S7 basic communication	14
— reserved for S7 basic communication	0
— adjustable for S7 basic communication, min.	0
— adjustable for S7 basic communication, max.	14
• usable for routing	X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 14; X2 as PROFINET: 24 max.

**S7 message functions**

Number of login stations for message functions, max.	16; Depending on the configured connections for PG/OP and S7 basic communication
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	300

**Test commissioning functions**

Status block	Yes; Up to 2 simultaneously
Single step	Yes
Number of breakpoints	4

**Status/control**

• Status/control variable	Yes
• Variables	Inputs, outputs, memory bits, DB, times, counters
• Number of variables, max.	30
— of which status variables, max.	30
— of which control variables, max.	14

**Forcing**

• Forcing	Yes
• Forcing, variables	I/O
• Number of variables, max.	10

**Diagnostic buffer**

• present	Yes
• Number of entries, max.	500; Only the last 100 entries are retentive at power on/off
— adjustable	No
— preset	10

**Potential separation**

between backplane bus and electronics	No
between backplane bus and all other circuit components	Yes
between supply and all other circuits	Yes

**Isolation**

Isolation tested with	In general, 707 V DC (type test), Ethernet interface 1 500 V AC (for P1 and P2 on CM, for P3 on IM)
-----------------------	---

**Degree and class of protection**

IP degree of protection	IP65/67
-------------------------	---------

**Standards, approvals, certificates**

CE mark	Yes
CSA approval	No
cULus	Yes
FM approval	No
RCM (formerly C-TICK)	Yes

**configuration / header**

Configuration software	
• STEP 7	Yes; V5.5 or higher

**configuration / programming / header**

• Command set	see instruction list
• Nesting levels	8
• System functions (SFC)	see instruction list
• System function blocks (SFB)	see instruction list

**Programming language**

— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes

**Know-how protection**

• User program protection/password protection	Yes
• Block encryption	Yes; With S7 block Privacy

**Dimensions**

Width	135 mm
Height	130 mm



Depth	65 mm; 60 mm without cover for RJ45 socket; 65 mm with cover for RJ45 socket
<b>Weights</b>	
Weight, approx.	720 g
<b>last modified:</b>	4/10/2024 