Data sheet 6ES7512-1SM03-0AB0



SIMATIC DP, CPU 1512SP F-1 PN for ET 200SP, central processing unit with 600 KB work memory for program and 2 MB for data, 1st interface: PROFINET IRT with 3-port switch, 25 ns bit performance, SIMATIC Memory Card required, BusAdapter required for port 1 and 2

General information	
Product type designation	CPU 1512SP F-1 PN
HW functional status	FS03
Firmware version	V3.1
FW update possible	Yes
Product function	
● I&M data	Yes; I&M0 to I&M3
 Module swapping during operation (hot swapping) 	Yes; Multi-hot swapping
 Isochronous mode 	Yes; only with PROFINET; with minimum OB $6x$ cycle of $500~\mu s$
SysLog	Yes
Engineering with	
STEP 7 TIA Portal configurable/integrated from version	V19 (FW V3.1) / V18 (FW V3.0) or higher; with older TIA Portal versions configurable as 6ES7512-1SK01-0AB0
Configuration control	
via dataset	Yes
Control elements	
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
Mains/voltage failure stored energy time	10 ms
Input current	
Current consumption (rated value)	0.48 A
Current consumption, max.	0.7 A
Inrush current, max.	1.34 A; Rated value
l²t	0.3 A ² ·s
Power	
Infeed power to the backplane bus	8.05 W
Power loss	
Power loss, typ.	3.5 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	600 kbyte
• integrated (for data)	2 Mbyte
Load memory	

Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	25 ns
for word operations, typ.	32 ns
for fixed point arithmetic, typ.	42 ns
for floating point arithmetic, typ.	170 ns
CPU-blocks	
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	2 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	2 Mbyte, 1 of bbs with absolute addressing, the max. Size is 04 Kb
Number range	0 65 535
• Size, max.	600 kbyte
FC	ooo kayta
Number range	0 65 535
• Size, max.	600 kbyte
• Size, max.	ooo nbyto
• Size, max.	600 kbyte
Number of free cycle OBs	100
Number of fime alarm OBs	20
Number of delay alarm OBs	20
Number of delay alarm OBs Number of cyclic interrupt OBs	
•	20; With minimum OB 3x cycle of 250 μs
Number of process alarm OBsNumber of DPV1 alarm OBs	50 3
	1
Number of isochronous mode OBs Number of technology aurebraness classes OBs	
Number of technology synchronous alarm OBs Number of startus OBs	2
Number of startup OBs Number of sourcebraneus error OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	24: Un to 9 pagaible for E blocks
• per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	0.040
• Number	2 048
Retentivity	Von
— adjustable	Yes
IEC counter	Any (only limited by the main
Number Potentivity	Any (only limited by the main memory)
Retentivity	Von
— adjustable	Yes
S7 times	2.040
Number Potentivity	2 048
Retentivity	Von
— adjustable	Yes
IEC timer	Any (only limited by the main
Number Potentivity	Any (only limited by the main memory)
Retentivity	V
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	256 kbyte; in total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 216 KB
Flag	ovalitors, DDS, and toorniology data (axes). 210 ND
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	o, a stock memory bit, grouped into one stock memory byte
Retentivity adjustable	Yes
■ INCICITUIVITY aujustable	100

Retentivity preset	No
Retentivity preset Local data	NO
	64 khyte: may 16 KB per block
per priority class, max. Address area	64 kbyte; max. 16 KB per block
	0.040 many much as af mandalas / submandalas
Number of IO modules	2 048; max. number of modules / submodules
I/O address area	0011 (411) (1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
• Inputs	32 kbyte; All inputs are in the process image
• Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	288 byte; For input and output data respectively
Address space per station	
Address space per station, max.	2 560 byte; for central inputs and outputs; depending on configuration; 2 048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	1
Number of IO Controllers	
• integrated	1
• Via CM	0
Rack	
Modules per rack, max.	82; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET 200AL modules
 Quantity of operable ET 200SP modules, max. 	64
 Quantity of operable ET 200AL modules, max. 	16
 Number of lines, max. 	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
• supported	Yes
• to DP, master	
o DI , mado	Yes: Via CM DP module
on DP device	Yes; Via CM DP module Yes: Via CM DP module
on DP, device in AS master	Yes; Via CM DP module
• in AS, master	Yes; Via CM DP module Yes
in AS, masterin AS, device	Yes; Via CM DP module Yes Yes
in AS, masterin AS, deviceon Ethernet via NTP	Yes; Via CM DP module Yes
 in AS, master in AS, device on Ethernet via NTP Interfaces	Yes; Via CM DP module Yes Yes Yes
 in AS, master in AS, device on Ethernet via NTP Interfaces Number of PROFINET interfaces	Yes; Via CM DP module Yes Yes Yes 1
in AS, master in AS, device on Ethernet via NTP Interfaces Number of PROFINET interfaces Number of PROFIBUS interfaces	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module
in AS, master in AS, device on Ethernet via NTP Interfaces Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface	Yes; Via CM DP module Yes Yes Yes 1
in AS, master in AS, device on Ethernet via NTP Interfaces Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface 1. Interface	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module
in AS, master in AS, device on Ethernet via NTP Interfaces Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface Interface Interface types	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module No
 in AS, master in AS, device on Ethernet via NTP Interfaces Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface Interface Interface types RJ 45 (Ethernet) 	Yes; Via CM DP module Yes Yes Yes Yes 1 1; Via CM DP module No Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45
 in AS, master in AS, device on Ethernet via NTP Interfaces Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface 1. Interface Interface types	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module No

BusAdapter (PROFINET)	Yes; compatible BusAdapters: BA 2x RJ45, BA 2x M12, BA 2x FC, BA 2x LC, BA LC/RJ45, BA LC/FC, BA 2x SCRJ, BA SCRJ/RJ45, BA SCRJ/FC
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
— Isochronous mode	Yes
Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
— Number of connectable IO Devices, max.	128; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Of which IO devices with IRT, max. 	64
 Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
— PROFINET Security Class	1
Update time for IRT	
— for send cycle of 250 μs	$250~\mu s$ to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— Isochronous mode	No
— IRT	Yes
— PROFlenergy	Yes; per user program
— Shared device	Yes
 Number of IO Controllers with shared device, max. 	4
 activation/deactivation of I-devices 	Yes; per user program
 Asset management record 	Yes; per user program
— PROFINET Security Class	SNMP Configuration and DCP Read Only
2. Interface	
Interface types	
• RS 485	Yes; Via CM DP module
Number of ports	1
Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP device	Yes
SIMATIC communication	Yes

 Number of connections, max. 	48; Of which 4 each reserved for ES and HMI
 max. number of DP devices 	125; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
Services	FROFIBUS UI FROFINET
	No
Equidistance Isochronous mode	No
activation/deactivation of DP devices	Yes
Interface types	165
RJ 45 (Ethernet)	Yes
• 100 Mbps	Yes
Autoregotiation Autoregoing	Yes
 Autocrossing Industrial Ethernet status LED 	Yes
RS 485	165
• Transmission rate, max.	12 Mbit/s
Protocols	12 MIDIUS
PROFIsafe	Voc. V2 4 1 V2 6
	Yes; V2.4 / V2.6
Number of connections	128: via integrated interfaces of the CDLL and connected CDs / CMs
 Number of connections, max. Number of connections reserved for ES/HMI/web 	128; via integrated interfaces of the CPU and connected CPs / CMs 10
Number of connections reserved for ES/Finiti/web Number of connections via integrated interfaces	88
Number of connections via integrated interfaces Number of connections per CP/CM	32
·	16
Number of S7 routing paths Redundancy mode	10
H-Sync forwarding	Yes
Media redundancy	165
Media redundancy	Yes; only via BusAdapter
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager;
WILA	MRP Client
 MRP interconnection, supported 	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
 Switchover time on line break, typ. 	200 ms; For MRP, bumpless for MRPD
 Number of stations in the ring, max. 	50
SIMATIC communication	
 PG/OP communication 	Yes; encryption with TLS V1.3 pre-selected
• S7 routing	Yes
Data record routing	Yes
 S7 communication, as server 	Yes
 S7 communication, as client 	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
 several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; max. 78 multicast circuits
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
• web API	
— Number of sessions, max.	50
 number of simultaneous HTTP calls, max. 	4

— HTTP request body, max.	131 072 byte
OPC UA	
Runtime license required	Yes; "Small" license required
OPC UA Client	Yes; Data Access (registered Read/Write), Method Call
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
 User authentication 	"anonymous" or by user name & password
 Number of connections, max. 	4
 Number of nodes of the client interfaces, recommended max. 	1 000
 Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_I max. 	300
 Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
 Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 Number of simultaneous calls of the client instructions for session management, per connection, max. 	1
 Number of simultaneous calls of the client instructions for data access, per connection, max. 	5
 Number of registerable nodes, max. 	5 000
 Number of registerable method calls of OPC_UA_MethodCall, max. 	100
 Number of inputs/outputs when calling OPC_UA_MethodCall, max. 	20
OPC UA Server	Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space
 Application authentication 	Yes
— Security policies	available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss
User authentication	"anonymous" or by user name & password
 — GDS support (certificate management) 	Yes
Number of sessions, max.	32
 Number of accessible variables, max. 	50 000
 Number of registerable nodes, max. 	10 000
 Number of subscriptions per session, max. 	50
— Sampling interval, min.	100 ms
— Publishing interval, min.	200 ms
 Number of server methods, max. 	20
 Number of inputs/outputs per server method, max. 	20
Number of monitored items, recommended max.Number of server interfaces, max.	4 000; for 1 s sampling interval and 1 s send interval 10 of each "Server interfaces" / "Companion specification" type and 20 of the
— Number of nodes for user-defined server interfaces,	type "Reference namespace" 15 000
max.	
Alarms and Conditions	Yes
 Number of program alarms 	100
Number of alarms for system diagnostics	50
Further protocols	
MODBUS	Yes; MODBUS TCP
S7 message functions	
Number of login stations for message functions, max.	32
number of subscriptions, max.	250
number of tags/attributes for subscriptions, max.	2 000
Program alarms	Yes
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max.	5 000
Number of simultaneously active program alarms	
Number of program alarms	600
 Number of alarms for system diagnostics 	100
 Number of alarms for motion technology objects 	160

Test commissioning functions	
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)
Single step	No
Number of breakpoints	8
Profiling	Yes
Status/control	1 05
	Vac without fail and
Status/control variable	Yes; without fail-safe
Variables	inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
Number of variables, max.	
— of which status variables, max.	200; per job
of which states variables, max.	200; per job
	200, per job
Forcing	Vac without fail age
• Forcing	Yes; without fail-safe
Forcing, variables	peripheral inputs/outputs (without fail-safe)
Number of variables, max.	200
Diagnostic buffer	
• present	Yes
 Number of entries, max. 	1 000
— of which powerfail-proof	500
Traces	
 Number of configurable Traces 	4
 Memory size per trace, max. 	512 kbyte
nterrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
Monitoring of the supply voltage (PWR-LED)	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC
Wolfor Control	program; selection guide via the TIA Selection Tool
 Number of available Motion Control resources for 	1 120
technology objects	
 Required Motion Control resources 	
 per speed-controlled axis 	40
 per positioning axis 	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis	
Number of positioning axes at motion control cycle	11
of 4 ms (typical value)	
of 4 ms (typical value) — Number of positioning axes at motion control cycle	14
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value)	14
of 4 ms (typical value) — Number of positioning axes at motion control cycle	14
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value)	14 Yes; Universal PID controller with integrated optimization
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller	
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact	Yes; Universal PID controller with integrated optimization
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step • PID-Temp	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step • PID-Temp Counting and measuring • High-speed counter	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step • PID-Temp Counting and measuring • High-speed counter Standards, approvals, certificates	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step • PID-Temp Counting and measuring • High-speed counter Standards, approvals, certificates Highest safety class achievable in safety mode	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature Yes
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step • PID-Temp Counting and measuring • High-speed counter Standards, approvals, certificates Highest safety class achievable in safety mode • Performance level according to ISO 13849-1	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature Yes
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step • PID-Temp Counting and measuring • High-speed counter Standards, approvals, certificates Highest safety class achievable in safety mode • Performance level according to ISO 13849-1 • SIL acc. to IEC 61508	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature Yes PLe SIL 3
of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) Controller • PID_Compact • PID_3Step • PID-Temp Counting and measuring • High-speed counter Standards, approvals, certificates Highest safety class achievable in safety mode • Performance level according to ISO 13849-1	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature Yes PLe SIL 3

High demand/continuous mode: PFH in accordance with SIL3	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-30 °C; No condensation
 horizontal installation, max. 	60 °C
 vertical installation, min. 	-30 °C; No condensation
 vertical installation, max. 	50 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— STL	Yes
— SCL	Yes
— CFC	Yes; either CFC or failsafe functionality
— GRAPH	Yes
Know-how protection	
 User program protection/password protection 	Yes
 Copy protection 	Yes
Block protection	Yes
Access protection	
 protection of confidential configuration data 	Yes
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Write protection for Failsafe 	Yes
 Protection level: Complete protection 	Yes
User administration	Yes; device-wide
programming / cycle time monitoring / header	
• lower limit	adjustable minimum cycle time
upper limit	adjustable maximum cycle time
Dimensions	
Width	100 mm
Height	117 mm
Depth	75 mm
Weights	
Weight, approx.	265 g

last modified:

7/9/2024