SIEMENS

Product data sheet 3NA3807



LV HRC FUSE LINK GL/GG WITH NON-INSULATED GRIP LUGS WITH FRONT INDICATOR SIZE 000, 20A, AC 500V/DC 250V

Similar to image

Technical data:		
product brand name		SENTRON
Product designation		LV HRC fuse link
Current / for AC / rated value	А	20
Operating class of the fuse link		gG
Size of the fallback-system / acc. to DIN EN 60269-1		NH000
Supply voltage		
• for AC / rated value	V	500
• for DC	V	250
Switching capacity current		
• in accordance with IEC 60947-2 / rated value	kA	120
• with DC / in accordance with IEC 60947-2 / rated value	kA	25
Design of the fuse link		LV HRC fuse link
Design of an identification indicator		Front indicators
Mounting type		Non-insulated grip lugs
mounting position		Any, preferably vertical
Protection class IP		IP20, with connected conductors
Climatic class		-20 to +50 at 95% relative humidity
Ambient temperature	°C	-5 +4 0

Ambient temperature / during storage / note		Air humidity 90% at 20 °C
Design of the switching contact		Non-corroding, silver-plated
Net weight	g	120
Item designation		
according to DIN EN 61346-2		F
according to DIN EN 81346-2		F

Certificates/approvals:

General Product Approval Declaration of Conformity Test Certificates





other





Special Test Certificate Type Test
Certificates/Test
Report

Shipping Approval



Environmental Confirmations

GL

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3NA3807

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3NA3807/all

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ ...)$


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3NA3807


CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

Datanorm GAEB81 GAEB83 RTF TXT





last change: Jul 14, 2014