SIEMENS

Data sheet

6GK7277-1AA10-0AA0

Product type designation



CSM 1277

COMPACT SWITCH MODULE CSM 1277 CONNECTION SIMATIC S7-1200 AND UP TO 3 FURTHER IND. ETHERNET USERS WITH 10/100 MBIT/S UNMANAGED SWITCH, 4 RJ45 PORTS, EXT. 24V DC POWER SUPPLY, LED DIAGNOSTICS, S7-1200 MODULE INCL. ELECTRONIC MANUAL ON CD

Transmission rate		
Transfer rate	10 Mbit/s, 100 Mbit/s	
Interferen		
Interfaces		
Number of electrical/optical connections		
 for network components or terminal equipment 	4	
/ maximum		
Number of electrical connections		
• for network components or terminal equipment	4	
Type of electrical connection		
• for network components or terminal equipment	RJ45 port	
Interfaces / for communication / integrated		
Number of 100 Mbit/s SC ports		
• for multimode	0	
Number of 1000 Mbit/s LC ports		
• for multimode	0	
• for single mode (LD)	0	
Interfaces / others		
Number of electrical connections		
for power supply	1	
Type of electrical connection		
• for power supply	3-pole terminal block	
Supply voltage, current consumption, power loss		
Type of voltage / of the supply voltage	DC	

24 V
19.2 28.8 V
Yes
0.5 A / 60 V
0.07 A
1.6 W

Permitted ambient conditions	
Ambient temperature	
 during operation 	0 60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
Relative humidity	
 at 25 °C / without condensation / during operation / maximum 	95 %
Protection class IP	IP20

Design, dimensions and weight	
Design	SIMATIC S7-1200 device design
Width	45 mm
Height	100 mm
Depth	75 mm
Net weight	0.15 kg
Mounting type	
• 35 mm DIN rail mounting	Yes
• wall mounting	Yes
• S7-300 rail mounting	No
 S7-1500 rail mounting 	No

Product functions / management, configuration	
Product function	
 multiport mirroring 	No
switch-managed	No

Standards, specifications, approvals	
Standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T, CL.1, Zone 2, GP. IIC, T Ta
• for hazardous zone	EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X
 for safety / from CSA and UL 	UL 508, CSA C22.2 No. 142
• for emitted interference	EN 61000-6-4 (Class A)
• for interference immunity	EN 61000-6-2

Certificate of suitability	EN 61000-6-2, EN 61000-6-4
● CE marking	Yes
• C-Tick	Yes
 KC approval 	No
Marine classification association	
 American Bureau of Shipping Europe Ltd. (ABS) 	No
Bureau Veritas (BV)	No
 Det Norske Veritas (DNV) 	No
 Germanische Lloyd (GL) 	No
 Lloyds Register of Shipping (LRS) 	No
 Nippon Kaiji Kyokai (NK) 	No
Polski Rejestr Statkow (PRS)	No
MTBF / at 40 °C	273 y

Further Information / Internet Links

Internet-Link

• to website: Selector SIMATIC NET **SELECTION TOOL**

• to website: Industrial communication

• to website: Industry Mall

• to website: Information and Download Center

• to website: Image database

• to website: CAx Download Manager

• to website: Industry Online Support

http://www.siemens.com/snst

http://www.siemens.com/simatic-net

https://mall.industry.siemens.com

http://www.siemens.com/automation/net/catalog

http://automation.siemens.com/bilddb

http://www.siemens.com/cax

https://support.industry.siemens.com

Security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Thirdparty products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about

product updates as they occur, sign up for a product-specific newsletter. For more information, visit

http://support.automation.siemens.com. (V3.4)

last modified:

01.06.2015